

CERTIFICATE OF COMPLIANCE

Certificate Number 20180402-MH27530
Report Reference MH27530-20000802
Issue Date 2018-APRIL-02

Issued to: ROTH INDUSTRIES INC
268 BELLEW AVE S
WATERTOWN NY 13601

**This is to certify that
representative samples of**

NONMETALLIC TANKS FOR OIL-BURNER FUELS AND
OTHER COMBUSTIBLE LIQUIDS

Refer to addendum page for Models/Product

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL Subject 2258, Outline of Investigation for Nonmetallic
Tanks for Oil-Burner Fuels and Other Combustible Liquids
and CAN/ULC-S670-14 - Standard for Nonmetallic Tanks
for Oil Burner Fuels and Other Combustible Liquids.

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE


Certificate Number 20180402-MH27530
Report Reference MH27530-20000802
Issue Date 2018-APRIL-02

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Addendum -

USL, CNL - Aboveground, nonmetallic, rectangular, diked (USA tank identifier)/closed secondary containment (Canadian tank identifier) tanks (nonmetallic primary tank within a metallic dike), with integral support and handles, for oil-burner fuels and other combustible liquids, for indoor or outdoor use for the following Models: 400L (400L/110 USG), 620L (620 L/165 USG), 1000L (1000 L/275 USG), 1000LH (1000 L/275 USG) and 1500L (1500 L/400 USG).

NOTE: This UL/ULC Listing covers only the tank design(s) indicated above. Any additional tank designs and models will require separate evaluation and approval prior to labelling with the UL/ULC mark.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

