

# ROTH INDUSTRIES, INC.

Manufacturer of Double-Wall Oil Storage Tanks, Radiant Heating, PEX Plumbing, Solar Systems and Heat Pumps



Part #

## Submittal Data Information

Roth Vent Alarm

Effective: September 2007

Supersedes:

Job: \_\_\_\_\_ Engineer: \_\_\_\_\_ Contractor: \_\_\_\_\_ Rep: \_\_\_\_\_

ITEM PART NO.	ITEM DESCRIPTION	MANUFACTURER
		Roth

All tanks shall be vented must have a Roth Vent Alarm (Part # 2350000999) installed unless another UL ® listed and approved level detection system for filling is used.

The Roth Vent Alarm is provided with a 2" NPT opening for the assembly of the vent pipe. The Roth whistle is installed on one of the openings on top of the tank and replaces one of the 2" NPT plastic adapters. Each whistle is sent with a gasket already installed.

Follow the directions referred to in the installation manual under vent piping to connect the vent pipe assembly to the Vent Alarm and to install the assembly in the tank.

The vent pipe must not reduce in any way the flow of air out of the tank. Roth strongly recommends the use of a venting pipe of 2" for all cases. It is possible that local codes allow variations. Consult your local codes, and NFPA 31 or CSA-B139 (depending upon national jurisdiction) for details about any allowable vent pipe diameter variations.

